

“The Public Authority for Applied Education and Training”

Researcher:

Eng. Mohammad A Alobaid

Construction Training Institute

Mechanical Works Department



1. Abstract:

This report details the cooling load calculations for a single-story villa with a basement located in Adan, Kuwait, considering the peak design conditions at 3:00 pm solar time, as per ASHRAE standards. The comprehensive analysis encompasses the assessment of total conduction, solar radiation, and internal thermal energies across various rooms and areas within the villa. Conduction heat transfer is examined in the building envelope including walls, glass, doors, partitions, and ceilings, while solar heat gains are calculated exclusively for glass surfaces. Internal loads are attributed to occupants, lighting, and equipment. By aggregating the solar radiation, conduction, and internal loads, the report determines the total energy influx into the villa, from which the requisite air conditioning capacity is derived to maintain indoor comfort. The findings provide crucial insights for designing efficient cooling systems tailored to the harsh climatic conditions of Kuwait.

2. Introduction:

Heat loss calculations are made to determine a building heating load. Under the fairly static conditions experienced under the assumptions used to make such calculations, heat loss and a heating load are functionally identical. Heat loss (the simultaneous summation of all heat flows out of a building) is synonymous with heating load (the capacity of equipment required to account for such a load). The same is not true of a heat gain and a cooling load. Heat gain is a simultaneous summation of all heat flows into a building along with those flows generated inside the building. Cooling load is the capacity of equipment required to account for such a load. Due to the dynamic nature of heat gain and the opportunities for heat storage (capacitance) that accompany dynamic loads, heat gain is often not equal to cooling load. Gains that enter a building but are stored in materials or furnishings do not have to be handled at that time and are not included in cooling load. In general, convective and latent heat flows are instantaneous, flow equals load. Radiant loads tend to be partially stored in a building (what percentage depends upon a number of factors), flow does not equal load. As with heat loss, it is necessary to calculate a design load to characterize building performance during over-heated period (normally summer) conditions. Design cooling load calculations are normally made to size HVAC (heating, ventilating, and air-conditioning) systems and their components. A building experiences a range of cooling loads in any given year, ranging in magnitude from zero (no cooling required) to whatever the maximum load happens to be that year. A design cooling load is a load near the maximum magnitude, but is not normally the maximum. This should become clear when the assumptions behind the calculations are understood. Design cooling load is intended to summarize all the cooling loads experienced by a building under a specific set of assumed conditions.

The assumptions behind design cooling load are as follows:

1. Weather conditions are selected from a long-term statistical database. The conditions will not necessarily represent any actual year, but are representative of the location of the building. ASHRAE has tabulated such data, as have other groups. The designer may select a severity of weather that seems appropriate for the building type in question although energy codes often specify what data shall be used (to minimize over-sized systems).
2. The solar loads on the building are assumed to be those that would occur on a clear day in the month chosen for the calculations.
3. The building occupancy is assumed to be at full design capacity.
4. All building equipment and appliances are considered to be operating at a reasonably representative capacity.
5. Lights are assumed to be operating as expected for a typical day of design occupancy.
6. Latent as well as sensible loads are considered.
7. Heat flow is analyzed assuming dynamic conditions, which means that heat storage in building envelope and interior materials is considered.

The above assumptions make calculation of design cooling load much more complicated and complex than calculations of design heat loss (with its many simplifying assumptions). Unfortunately, there is no way around this--especially in a cooling

load dominant climate as occurs in much of the southern United States. The total building cooling load will involve heat transferred through the building envelope and heat generated by occupants, equipment, and lights. The envelope heat flows are termed external loads, in that they originate with the external environment. The other loads are termed internal loads, in that they are generated from within the building itself. The percentage of external versus internal load varies with building type, site climate, and building design decisions. The total building cooling load also consists of sensible load components and latent load components. The sensible loads will affect dry bulb air temperature; the latent loads will affect absolute (and relative) humidity. Buildings are classified as envelope-load-dominated and interior-load-dominated. Envelope-dominated buildings (also called external-load-dominated) experience the majority of their cooling loads as a result of the interaction between the exterior environment and the interior environment. Interior (or internal) load-dominated buildings experience the majority of their cooling loads as a result of activities occurring within the building. It is useful to be able to predict whether a building will be dominated by internal or external loads as this information should substantially change the focus of design efforts related to energy efficiency.

3. Objective:

1. To determine cooling load of a residential building.
2. To learn how to master the cooling load calculations.

4. Basement Calculations:

4.1 Total cooling load for below- grade room:

		Item	Orientation	Area, ft ²	U Btu/hr.ft ² .F	CLTD, °F		Total Cooling, Btu/hr		
		External LOADS	Conduction	Wall	E	131.81	0.107	43.15		608.5734
Wall	N			199.06	0.107	28.15		599.5787		
Glass	E			27.438	0.65	32.15		573.3856		
Partition (wall)	-			119.436	0.2	Δt	19	453.8568		
Partition (wall)	-			39.812	0.2	Δt	0	0		
Partition (wall)	-			147.3044	0.2	Δt	0	0		
Partition (wall)	-			19.906	0.2	Δt	0	0		
Partition (door)	-			21.52	0.57	Δt	0	0		
Total Conduction								2235.395		
External LOADS	Solar			Item	Orientation	Area, ft ²	SC	Max SHG	CLF	
		Glass (shaded)	N	27.438	0.73	45	0.2	180.27		
		Total Solar								180.27
Internal loads	Item	N	HG	CLF	Load Limit					
	People									
	Sensible	5	710	1		3550				
	Latent	5	1090	1		5450				
	Lights	12	1964.16	1		1964.16				
	Equipments									
	TV	1	256	0.83		212.48				
	Receiver	1	102.4	0.83		84.992				
	DVD	1	61.43	0.56		34.4008				

Ventilation	N	Q, cfm/person	$\Delta t, ^\circ F$	ΔW	
Sensible	5	15	39.8	-	3283.5
Latent	5	15	-	0.01	3630
Total Internal Load					18209.53
TOTAL LOAD					20625.195

4.2 Total cooling load for Below- grade living room:

External LOADS	Conduction	Item	Orientation	Area, ft ²	U Btu/hr.ft ² .F	CLTD, °F		Total Cooling, Btu/hr
		Wall	N	495.6594	0.107	28.15		1492.951
Wall	W	513.3488	0.107	33.15		1820.874		
Wall	S	756.428	0.107	33.15		2683.088		
Wall	E	119.436	0.107	43.15		551.442		
Wall	E	27.8684	0.107	43.15		128.6698		
Wall	N	73.6522	0.107	28.15		221.8441		
Wall	E	29.59	0.107	43.15		136.6185		
Glass	S	11.9436	0.65	32.15		249.5914		
Glass	W	11.9436	0.65	32.15		249.5914		
Glass	S	11.9436	0.65	32.15		249.5914		
Glass	W	15.12856	0.65	32.15		316.1491		
Below grade	-	189.376	0.0489	Δt	19	176		
Partition (wall)	-	2868.186	0.2	Δt	0	0		
Door	-	1743.981	0.6	Δt	19	19881.38		

		Floor	-	19.906	0.145	Δt	19	54.84
		Partition (wall)	-	19.906	0.2	Δt	0	0
		Partition (wall)	-	93.5582	0.2	Δt	0	0
		Partition (wall)	-	39.812	0.2	Δt	0	0
		Partition (wall)	-	119.436	0.2	Δt	19	453.8568
		Partition (wall)	-	18.292	0.2	Δt	0	0
		Partition (door)	-	17.216	0.57	Δt	19	186.4493
		Total Conduction						
	Solar	Item	Orientation	Area, ft²	SC	Max SHG	CLF	
		Glass (shaded)	N	11.9436	0.73	45	0.4	156.94
		Glass (sunlit)	W	7.76	0.73	215	0.53	645.504
		Glass (shaded)	N	4.18	0.73	45	0.2	27.46
		Glass (shaded)	N	5.3	0.73	45	0.2	34.82
		Glass (shaded)	N	11.9436	0.73	45	0.4	156.94
		Glass (sunlit)	W	9.833	0.73	215	0.53	817.94
Total Solar							1839.604	
Internal loads	Item	N	HG	CLF	Load Limit			
	People							
	Sensible	15	710	1		10650		
	Latent	15	1090	1		16350		
	Lights	44	7201.92	1		7201.92		

Equipments					
TV	1	256	0.83		212.48
Receiver	1	102.4	0.83		84.992
DVD	1	61.43	0.56		34.4008
Ventilation	N	Q, cfm/person	$\Delta t,$ °F	ΔW	
Sensible	15	15	39.8	-	9850.5
Latent	15	15	-	0.01	10890
Total Internal Load					55274.29
TOTAL LOAD					85966.834

4.3 Total Cooling Load for Basement:

Item	Cooling Load (Btu/hr)
Room	20,625.195
Living Room	85,966.834
Total	106,592.03
Total Cooling Load in tons	8.88

1. Ground Floor Calculations:

5.1 Living Room:

	Item	Orientation	Area, m ²	U Btu/hr.ft ² . F	CLTD, °F		Total Cooling, Btu/hr
External LOADS	Wall 1,2,4,6,7,10,IIW,P1 door	E	25.952	0.107	28.15		841.095444
	Wall 3,IIIW,11,4W,12,13b,15,16,18 ,P2 door	S	31.102	0.107	33.15		1187.04696
	Wall	N	44.474	0.107	28.15		1441.38713
	Wall 5,17	SE	13.394	0.107	40.15		619.14432
	Wall 14	SW	5.143	0.107	33.15		196.289065
	Wall	NE	8.436	0.107	37.15		360.820695
	Glass 1	E	3.043	0.65	32.15		684.240155
	Glass 2	E	3.9201	0.65	32.15		881.462318
	Glass 3	S	3.9201	0.65	32.15		881.462318
	Glass 4	S	3.18	0.65	32.15		715.045578
	Partition 1,2 (doors)	-	11.064	0.6	Δt	19	1357.20356
	Partition (Wall) p2,p3,p4,p5	-	25.53	0.2	Δt	0	0
	Partition (Wall) P6,p7	-	10.693	0.2	Δt	19	437.215384
	Partition 3 (Bathroom door)	-	1.8	0.57	Δt	19	209.75544
	Partition 5 (Bathroom door)	-	1.8	0.57	Δt	19	209.75544
	Ceiling	-	152.96	0.078	Δt	0	0
Floor	-	152.96	0.078	Δt	0	0	
Total Conduction							10021.924
External LOADS	Item	Orientation	Area, m ²	SC	Max SHG	CLF	
	Glass 1 (shade)	N	3.043	0.73	45	0.20	215.119408
	Glass 2 (shade)	N	3.9201	0.73	45	0.20	277.124413
	Glass 3 (shade)	N	3.9201	0.73	45	0.20	277.124413
	Glass 4 (shade)	N	3.18	0.73	45	0.20	224.804376
Total Solar							994.17261
Internal loads	Item		N	HG	CLF	Load Limit	
	People						
	Sensible		30	245	1		7350
	Latent		30	155	1		4650
	Lights		75	12276	1		12276
	Ventilation		N	Q ,cfm/person	Δt , °F	ΔW	
	Sensible		30	15	39.8	-	19701
	Latent		30	15	-	0.01	21780
Total Internal Load							65757
TOTAL LOAD							76773.1

5.2 Room:

External LOADS	Conduction	Item	Orientation	Area, m ²	U ,Btu/hr.ft ² .F	CLTD , °F		Total Cooling, Btu/hr	
		Wall a	W	9.916	0.107	33.15			378.456614
Wall (W1)	W	2.7029	0.107	33.15			103.159579		
Wall (W2)	S	2.7029	0.107	33.15			103.159579		
Wall b	S	9.916	0.107	33.15			378.456614		
Glass 1	W	3.9201	0.650	32.15			881.462318		
Glass 2	S	3.9201	0.650	32.15			881.462318		
Partition 1 (doors)	-	1.8	0.570	Δt	0		0		
Partition (Wall)	-	16.65	0.200	Δt	0		0		
Partition (Wall)	-	6.845	0.200	Δt	19		279.87836		
Partition (Wall)	-	4.44		Δt	0		0		
Ceiling	-	20.25	0.078	Δt	0		0		
Floor	-	20.25	0.078	Δt	0		0		
Total Conduction								3006.03538	
External LOADS	Solar	Item	Orientation	Area, m ²	SC	Max SHG	CLF		
		Glass 1 (shade)	N	3.9201	0.73	45	0.20	277.124413	
Glass 2 (shade)	N	(0.1) 3.9201	0.73	45	0.20	27.7124413			
Glass 2 (sunlit)	W	(0.9) 3.9201	0.73	215	0.53	3157.83269			
Total Solar								3462.66954	
Internal loads	Internal loads	Item		N	HG	CLF			
		People							
		Sensible		6	245	1			1470
		Latent		6	155	1			930
		Lights		10	1636.8	1			8184
		Appliances							
		TV		1	256	0.83			212.48
		Receiver		1	102.4	0.83			84.992
		Ventilation		N	Q , cfm/person	Δt , °F	ΔW		
		Sensible		6	15	39.8	-		3940.2
		Latent		6	15	-	0.01		4356
Total Internal Load								8296.2	
TOTAL LOAD								14764.9	

5.3 Kitchen:

External LOADS	Conduction	Item	Orientation	Area, m ²	U , Btu/hr.ft ² .F	CLTD , °F		Total Cooling, Btu/hr
		Wall a	W	11.026	0.107	33.15		
Wall b	W	3.58	0.107	33.15			136.635204	
Glass c	W	3.043	0.650	32.15			684.240155	
Wall c	W	1.11	0.107	33.15			42.3645464	
Partition 4	-	11.47	0.2	Δt	0		0	
Partition 8	-	4.07	0.2	Δt	0		0	
Partition 9,10,11,12,15	-	37.444	0.2	Δt	0		0	

	Partition (door)	-	1.8	0.57	Δt	0	0
	Partition 13	-	11.026	0.2	Δt	19	450.831088
	Partition 14	-	8.066	0.2	Δt	0	0
	Partition (door)	-	1.8	0.57	Δt	19	209.75544
	Partition 16	-	12.95	0.2	Δt	19	529.4996
	Ceiling	-	59.375	0.078	Δt	0	0
	Floor	-	59.375	0.078	Δt	0	0
	Total Conduction						
Solar	Item	Orientation	Area, m ²	SC	Max SHG	CLF	
	Glass (sunlit)	W	(0.75)3.043	0.73	215	0.53	2042.73804
	Glass (shade)	N	(0.25)3.043	0.73	45	0.20	53.7798519
	Total Solar						
Internal loads	Item		N	HG		CLF	
	People						
	Sensible		10	245		1	2450
	Latent		10	155		1	1550
	Lights		20	3273.6		1	3273.6
	Appliances						
	Refrigerator						
	Sensible		-	300		1	300
	Latent		-	0		1	
	Freezer						
	Sensible		-	1840		1	1840
	Latent		-	0		1	
	Microwave						
	Sensible		-	8970		0.64	5740.8
	Latent		-	0		0.64	0
	Gas Oven						
	Hooded		-	250		0.71	177.5
	Ventilation		N	Q , cfm/person		Δt , °F	ΔW
Sensible		10	15		39.8	-	6567
Latent		10	15		-	0.01	7260
Total Internal Load							29158.9
TOTAL LOAD							33729.57

5.4 Total Cooling Load For Ground Floor:

Item	Cooling Load (Btu/hr)
Room	14,764.9
Living Room	76,773.1
Kitchen	33,729.57
Total	125,267.57
Total Cooling Load in tons	10.44

5. First Floor Calculations:

6.1 Total cooling load for Room1

		Item	Orientation	Area, ft ²	U Btu/hr.ft ² .F	CLTD, °F	Total Cooling,	
		External LOADS	Conduction	Wall	E	140.8	0.107	43.15
Wall	N			132.76	0.107	28.15	399.88	
Partition	-			201.152	0.2	ΔT=19	764.377	
Partition	-			60.34	0.2	ΔT=19	229.292	
Partition	-			28.161	0.2	ΔT=0	0	
Partition	-			80.461	0.2	ΔT=0	0	
Partition	-			48.276	0.2	ΔT=0	0	
Partition	-			48.276	0.2	ΔT=0	0	
Glass	E			34.3	0.65	215	4793.425	
Glass	N			22.867	0.65	45	668.86	
Glass	E			22.867	0.65	32.15	477.86	
Door	-			21.174	0.57	ΔT=0	0	
Door	-			21.174	0.57	ΔT=19	229.31	
Ceiling	-			415.3	0.078	43.15	1397.77	
Total Conduction							9610.854	
External LOADS	Solar	Item	Orientation	Area, ft ²	SC	Max SHC	CLF	
		Glass	N	22.867	0.73	45	0.20	150.2362
		Glass(Shade)	N	22.867	0.73	45	0.20	150.23
		Glass(Shade)	N	40.23	0.73	45	0.20	264.3111
		Total Solar						
Internal loads	Item	N	HG	CLF	Load Limit			
	People							
	Sensible	3	245	1		735		
	Latent	3	155	1		465		
	Lights	25	4092	1		4092		
	Equipment							
	TV	1	256	0.83		212.48		
	Receiver	1	102.4	0.83		84.992		
	DVD Player	1	61.43	0.56		34.4		
	Ventilation	N	Q, cfm	Δt, °F	ΔW			
	Sensible	3	15	39.8	-	1970.1		
	Latent	3	15	-	0.01	2178		
	Total Internal Load							9771.972
TOTAL LOAD							19947.61	

6.2 Total cooling load for Room2

		Item	Orientation	Area, ft ²	U Btu/hr.ft ² .F	CLTD , °F	Total Cooling, Btu/hr
		Conduction	Wall	S	189.08	0.107	33.15
Wall	W		160.922	0.107	33.15	570.79	
Partition	-		100.57	0.2	ΔT=19	382.16	
Partition	-		40.23	0.2	ΔT=19	152.87	
Glass	W		34.301	0.65	32.15	716.8	
Glass	S		34.301	0.65	32.15	716.8	
Door	-		21.17	0.57	ΔT=0	0	
Door	-		21.17	0.57	ΔT=19	229.27	
Ceiling	-		224.884	0.078	43.15	756.87	
Total Conduction							4196.288
Solar	Item	Orientation	Area, ft²	SC	Max SHG	CLF	
	Glass (shade)	N	22.867	0.73	45	0.20	150.24
	Glass (shade)	N	22.867	0.73	45	0.20	150.24
	Total Solar						
Internal loads	Item		N	HG	CLF	Load Limit	
	People						
	Sensible		3	245	1		735
	Latent		3	155	1		465
	Lights		20	3264	1		3264
	Equipments						
	TV		1	256	0.83		212.48
	DVD Player		1	61.43	0.56		34.4
	Receiver		1	102.4	0.83		84.99
	Ventilation		N	Q, cfm	Δt , °F	ΔW	
	Sensible		3	15	39.8	-	1970.1
	Latent		3	15	-	0.01	2178
Total Internal Load							8943.97
TOTAL LOAD							13440.7304

6.3 Total cooling load for Room3

		Item	Orientation	Area, ft ²	U Btu/hr.ft ² .F	CLTD, °F	Total Cooling, Btu/hr		
		External LOADS	Conduction	Partition	-	100.576	0.2	ΔT=19	382.1888
Partition	-			120.69	0.2	ΔT=19	458.622		
Wall	S			160.92	0.107	33.15	570.79		
Wall	W			120.67	0.107	33.15	428.022		
Glass	W			34.301	0.65	32.15	716.8		
Glass	S			34.301	0.65	32.15	716.8		
Door	-			16.939	0.57	ΔT=19	183.449		
Door	-			21.17	0.57	ΔT=0	0		
Ceiling	-			330.81	0.078	43.15	1113.4		
Total Conduction							4570.09		
External LOADS	Solar			Item	Orientation	Area, ft ²	SC	Max SHG	CLF
		Glass	S	34.3	0.73	98.5	0.94	2318.36101	
		Glass	N	34.3(0.1)	0.73	45	0.20	22.5351	
		Glass	W	34.3(0.9)	0.73	215	0.53	2567.87465	
		Total Solar							5171.555
Internal loads	Item	N	HG	CLF	Load Limit				
	People								
	Sensible	3	245	1		735			
	Latent	3	155	1		465			
	Lights	10	1636.8	1		1636.8			
	Equipments								
	TV	1	256	0.83		212.48			
	DVD Player	1	61.43	0.56		34.4			
	Receiver	1	102.4	0.83		84.992			
	Ventilation	N	Q, cfm	Δt, °F	ΔW				
	Sensible	3	15	39.8	-	1970.1			
	Latent	3	15	-	0.01	2178			
Total Internal Load							7316.772		
TOTAL LOAD							16795.63		

6.4 Total cooling load for Room4

		Item	Orientation	Area, ft ²	U Btu/hr.ft ² .F	CLTD, °F		Total Cooling, Btu/hr
			Partition	-	100.576	0.2	ΔT=19	
	Partition	-	104.6	0.2	ΔT=19		397.48	
	Wall	N	112.645	0.107	28.15		339.3	
	Wall	W	144.83	0.107	33.15		513.72	
	Glass	N	34.301	0.65	32.15		716.8	
	Glass	W	34.301	0.65	32.15		716.8	
	Door	-	21.17	0.57	ΔT=0		0	
	Ceiling		258.64	0.078	43.15		870.5	
	Total Conduction							3936.7926
External LOADS	Solar	Item	Orientation	Area, ft ²	SC	Max SHG	CLF	
		Glass	N	34.3	0.73	45	0.20	225.351
		Glass	N	34.3(0.1)	0.73	45		22.5351
		Glass	W	34.3(0.9)	0.73	215		2567.87465
		Total Solar						
Internal loads	Item	N	HG	CLF	Load Limit			
	People							
	Sensible	3	245	1		735		
	Latent	3	155	1		465		
	Lights	10	1636.8	1		1636.8		
	Equipments							
	TV	1	256	0.83		212.48		
	DVD Player	1	61.43	0.56		34.4		
	Receiver	1	102.4	0.83		84.992		
	Ventilation	N	Q, cfm	Δt, °F	ΔW			
	Sensible	3	15	39.8	-	1970.1		
Latent	3	15	-	0.01	2178			
Total Internal Load							7316.772	
TOTAL LOAD							14069.3207	

6.5 Total cooling load for Room5

External LOADS	Conduction	Item	Orientation	Area, ft ²	U Btu/hr.ft ² .F	CLTD , °F		Total Cooling, Btu/hr
		Partition	-	108.622	0.2	ΔT=19		412.7636
Partition	-	80.461	0.2	ΔT=19		305.75		
Wall	N	96.55	0.107	28.15		290.8134		
Glass	N	34.301	0.65	32.15		716.8		
Door	-	21.17	0.57	ΔT=0		0		
Ceiling	-	177.26	0.078	43.15		596.6		
Total Conduction							2322.73	
External LOADS	Solar	Item	Orientation	Area, ft ²	SC	Max SHG	CLF	
		Glass	N	34.3	0.73	45	0.2	225.351
Total Solar							225.351	
Internal loads	Item	N	HG	CLF	Load Limit			
	People							
	Sensible	3	245	1		735		
	Latent	3	155	1		465		
	Lights	10	1636.8	1		1636.8		
	Equipments							
	TV	1	256	0.83		212.48		
	DVD Player	1	61.43	0.56		34.4		
	Receiver	1	102.4	0.83		84.99		
	Printer	1	1500	0.56		840		
	Mini-Computer	1	1000	0.82		820		
	Ventilation	N	Q, cfm	Δt , °F	ΔW			
	Sensible	3	15	39.8	-	1970.1		
	Latent	3	15	-	0.01	2178		
Total Internal Load						8976.77		
TOTAL LOAD							11524.85	

6.6 Total cooling load for living room

External LOADS	Conduction	Item	Orientation	Area, ft ²	U Btu/hr.ft ² .F	CLTD , F		Total Cooling, Btu/hr
		Partition	-	120.69	0.2	ΔT=19		458.622
		Partition	-	52.3	0.2	ΔT=19		198.47
		Wall	SW	56.86	0.107	33.15		201.68
		Wall	SE	56.86	0.107	40.15		244.273
		Glass	S	21.173	0.65	32.15		442.46
		Glass	S	21.173	0.65	32.15		442.46
		Glass	S	21.173	0.65	32.15		442.46
		Glass	S	21.173	0.65	32.15		442.46
		Ceiling	-	815.932	0.078	43.15		2746.18
		Total Conduction						
External LOADS	Solar	Item	Orientation	Area, ft ²	SC	Max SHG	CLF	
		Glass	N	21.173	0.73	45	0.20	139.10661
		Glass	N	21.173	0.73	45	0.20	139.10661
		Glass	N	21.173	0.73	45	0.20	139.10661
		Glass	N	21.173	0.73	45	0.20	139.10661
		Total Solar						
Internal loads	Item	N	HG	CLF	Load Limit			
	People							
	Sensible	7	245	1		1715		
	Latent	7	155	1		1085		
	Lights	60	9792	1		9792		
	Equipments							
	TV	1	256	0.83		212.48		
	DVD Player	1	61.43	0.56		34.4		
Receiver	1	102.4	0.83		84.99			

Mini-Computer	1	1000	0.82		820
Ventilation	N	Q, cfm	Δt ,°F	ΔW	
Sensible	7	15	39.8	-	4596.9
Latent	7	15	-	0.01	5082
Total Internal Load					13743.87
TOTAL LOAD					25087.335

6.7 Total Cooling Load in First Floor:

Item	Cooling Load (Btu/hr)
Room 1	19,947.61
Room 2	13,440.7304
Room 3	16,795.63
Room 4	14,069.3207
Room 5	11,524.85
Living Room	25,087.335
Total Cooling Load	100,865.476
Total Cooling Load in tons	8.41

7. Villa total cooling load:

Floor	Cooling Load (Btu/hr)
Basement	106,592.03
Ground	125,267.57
First	100,865.476
Total Cooling Load	332,725.08
Total Cooling Load in tons	27.73

8. Sample Calculations:

8.1 Design Conditions (summer):

- **Outdoor Design condition :** 115°F (DB) , 69°F (WB) , 28% (RH) , 0.0173w
- **Indoor Design condition :** 76°F (DB) , 62°F (WB) , 50% (RH) , 0.0093 (w)
- **Daily Range :** 27.7⁰ F
- **Ground Temperature :** 35°C
- **Latitude :** 29.5° North
- **Solar Time :** 15:00 hr
- **July 21st**

8.2 External Parameters:

8.2.1 Roof:

Assume 4 in. wood with 2 in. insulation

$U = 0.078 \text{ Btu/hr.ft}^2.\text{°F}$ (Table28)

CLTD = 24°F (Table 29), with suspended ceiling

$$CLTD_{corr} = [(CLTD + LM)K + (78 - t_R) + (t_o - 85)]f$$

LM = 1 (table 32)

f = 1 (ducts)

K = 1 (Dark colored area)

$t_o = 115 - 27.7/2 = 101.15\text{°F}$

$$CLTD_{corr} = 43.15\text{° F}$$

8.2.2 Wall:

Assume **Group B** (4 in Face Brick + 2 in. insulation + 8 in concrete block) → Table 30

→ **$U = 0.107 \text{ Btu/hr.ft}^2.\text{°F}$**

$$CLTD_{corr} = [(CLTD + LM)K + (78 - t_R) + (t_o - 85)]$$

Orientation	CLTD values From Table 31 (°F)		Corrected CLTD (°F)
North	9	→	28.15
East	24		43.15
South	14		33.15
West	14		33.15
South-East	21		40.15
South-West	14		33.15
North-East	18		37.15

- **Below-Grade:**
From table 5.9 at depth 3.2 m, using extrapolation → **$U = 0.0489 \text{ Btu/hr.ft}^2.\text{°F}$**
- **Basement Floor:**
From table 5.9 at depth 3.2 m, using extrapolation → **$U = 0.145 \text{ Btu/hr.ft}^2.\text{°F}$**
- **Partition (Wall):**
Assume (4 in Heavy weight concrete + 2 in. insulation) Group D → **$U = 0.200 \text{ Btu/hr.ft}^2.\text{°F}$**
- **Partition (Door):**
 - **Outside Doors :** assume 1 3/4 steel door + fiberglass without thermal break
→ **$U = 0.6 \text{ Btu/hr.ft}^2.\text{°F}$** (table 5.8)
 - **Inside Doors :** assume wood 1 3/8 solid core flush door
→ **$U = 0.57 \text{ Btu/hr.ft}^2.\text{°F}$** (table 5.8)

8.2.3 Windows:

- Assume double glazing ,Aluminum with thermal break, ¼ in. air space → U from table 5-5a **0.65 Btu/hr.ft².°F**
- CLTD from table 33 is 14° F → **$CLTD_{corr} = 32.15^\circ \text{ F}$**
- Max. SHGF:

Orientation	Max. SHGF values From Table 34 (Btu/hr.ft ²)
North	45
East	215
South	98.5
West	215

- **CLF :Assume Uncarpeted Floors**

Orientation	CLF values From Table 38
North	0.2
East	0.21
South	0.94
West	0.53

- **SC = 0.73** (Assume open wave fabric and medium colored)

From figure 7.12 → I_m → between C and D

Table 7.5 → Choose (C), insulating glass ¼ in. air space → SC = 0.73

8.3 Internal Parameters:

8.3.1 Lights:

CLF = 1 (24 hr operation)

W = 40 watts, $F_{ul} = 1$ (24 hr operation) , $F_{sa} = 1.2$

8.3.2 People :

Table 3 for seated, very light work

(HG)_{sensible} = 245 BtU/hr , **(HG)_{latent} = 155 BtU/hr**

CLF = 1 (24 hr operation)

8.3.3 Equipments:

- **Kitchen: unhooded ,table 8**

Refrigerator: (HG)_{sensible} = 300 BtU/hr , **(HG)_{latent} = 0 BtU/hr**

Microwave : (HG)_{sensible} = 8,970 BtU/hr , **(HG)_{latent} = 0 BtU/hr**

Freezer: (HG)_{sensible} = 1,840 BtU/hr , **(HG)_{latent} = 0 BtU/hr**

Gas Oven: (HG)_{hooded} = 250 BtU/hr

CLF values: table 48

Refrigerator: CLF = 1 (24 hr Operation)

Microwave : CLF = 0.64 (2 hr operation and from 2:00 pm to 3:00 pm)

Freezer: CLF = 1 (24 hr Operation)

Gas Oven: CLF = 0.71 (9:00 am to 5:00 pm)

- **Room: table 9**

Mini-Computer: HG = 1000 BtU/hr

Printer: HG = 1500 BtU/hr

CLF Values: table 48

Mini-Computer: CLF = 0.82 (10 hr operation, from 10:00 am to 10:00 pm)

Printer: CLF = 0.56 (2 hr operation time, from 2:00 pm to 3:00 pm)

- **External Data: (internet or manual work)**

TV: HG = 75 W = 3.4129×75 = 256 BtU/hr

Receiver: HG = 30 W = 102.4 BtU/hr

DVD Player: HG = 18 W = 61.43 BtU/hr

CLF Values: table 48

For TV and receiver CLF = 0.83 (from 9:00 am to 11:00 pm)

For DVD player CLF = 0.56 (from 2:00 pm to 4:00 pm)

8.4 Ventilation:

$$Q = 15 [\text{CFM/Person}] \times N$$

$$\Delta W = 0.01, \Delta t = 39.8^\circ \text{ F}$$

$$q_{latent} = 4840 Q \Delta W, \quad q_{sensible} = 1.1 Q \Delta t$$

9. Discussion & Conclusion

1. Total cooling load was evaluated to be 27.73 tons for a 380 m² villa using CLTD method.
2. The cooling load for the first floor is 8.4 tons, 10.4 tons for ground floor and 8.9 tons for the basement.
3. The smallness of this value may be due to totally shading on most of the windows and/or because of draperies or internally shading.
4. The ground floor has the maximum cooling load, and account for nearly 37.5% of the total cooling load that is due high internal loads.
5. The ground floor requires the maximum amount of cooling while the first floor and the basement require the minimum amount of cooling.
6. The orientation of each wall and glass takes an important rule to calculate the cooling load.
7. The wall, which means the wall that separate the outside environment from inside condition at the home has higher insulation material than the partition which is used between two rooms in the floor.
8. The wall must have high insulation material than the partition because it expose to humidity, water, dust and solar radiation.
9. Very small areas compared with others may be ignored if found to have minute influence.
10. As A.C. engineers we should be able to calculate the cooling load required for a space, to determine the satisfactory HVAC System.
11. Internal and external shading play an important role in the cooling load reduction.
12. Windows facing south, east and north are totally shaded while windows facing west have 10-35% shading depending on the floor.
13. For a totally shaded glass a north orientation is used in our calculations.
14. The largest CLTD factor for the wall appears at east orientation so that the wall facing east has the largest conduction (CLTD=43.15).
15. The maximum solar heat gain factor for the windows appear at east and west ordinations (SHGF=215).

10. Villa Pictures:



Picture 1: totally shaded for windows facing south.



Picture 2: totally shaded for windows facing east.



Picture 3: 25% shaded window facing west.



Picture 4: 10% shading for window facing west (Ground Floor).



Picture 5: 10% shading for window facing west (First Floor).



Picture 6: 35% shading for window facing west (Basement).



Picture 7: totally shaded window facing east (Basement).



Picture 8: 20% shading for window facing west (First Floor).

11. References:

- Mirzaei, P. A., Olsthoorn, D., Torjan, M., & Haghghat, F. (2015). Urban neighborhood characteristics influence on a building indoor environment. *Sustainable Cities and Society*, 19, 403-413.
- Zhang, H., & von Hippel, F. N. (2000). Using commercial imaging satellites to detect the operation of plutonium-production reactors and gaseous-diffusion plants. *Science & Global Security*, 8(3), 261-313.
- Liao, Z., & Dexter, A. L. (2004). The potential for energy saving in heating systems through improving boiler controls. *Energy and buildings*, 36(3), 261-271.
- Minetto, S., & Fornasieri, E. (2011). An innovative system for feeding once-through evaporators in flooded conditions. *Applied thermal engineering*, 31(2-3), 370-375.
- Minetto, S., & Fornasieri, E. (2011). An innovative system for feeding once-through evaporators in flooded conditions. *Applied thermal engineering*, 31(2-3), 370-375.
- Asere, L., Mols, T., & Blumberga, A. (2016). Assessment of indoor air quality in renovated buildings of liepāja municipality. *Energy Procedia*, 91, 907-915.
- Wang, H., Huang, C., Cui, Y., & Zhang, Y. (2018). Experimental study on the characteristics of secondary airflow device in a large enclosed space building. *Energy and Buildings*, 166, 347-357.
- Khalifa, W., & El-Kashif, K. F. (2019). Computational Model for the Evaluation of Reinforced Concrete Silos Subjected to Thermal Load. *Engineering, Technology & Applied Science Research*, 9(4).
- Lemonsu, A., Bélair, S., Mailhot, J., & Leroyer, S. (2010). Evaluation of the Town Energy Balance model in cold and snowy conditions during the Montreal Urban Snow Experiment 2005. *Journal of Applied Meteorology and Climatology*, 49(3), 346-362.
- Alvarez, G., Palacios, M. J., & Flores, J. J. (2000). A test method to evaluate the thermal performance of window glazings. *Applied thermal engineering*, 20(9), 803-812.

12.Appendix




Figure1: The Basement




Figure2: The Ground Floor

"تحليل شامل لأحمال التبريد لتصميم التدفئة والتهوية وتكييف الهواء الأمثل في منطقة العدان، الكويت"

إعداد الباحث:

م. محمد العبيد

الملخص:

يعرض هذا التقرير تفاصيل حسابات أحمال التبريد لفيلا من طابق واحد مع طابق سفلي تقع في عدن، الكويت، مع الأخذ في الاعتبار ظروف التصميم القصوى عند الساعة 3:00 مساءً بالتوقيت الشمسي، وفقاً لمعايير ASHRAE. يشمل التحليل الشامل تقييم التوصيل الكلي والإشعاع الشمسي والطاقت الحرارية الداخلية عبر مختلف الغرف والمناطق داخل الفيلا. يتم فحص انتقال الحرارة بالتوصيل في غلاف المبنى بما في ذلك الجدران والزجاج والأبواب والفواصل والأسقف، في حين يتم حساب مكاسب الحرارة الشمسية حصرياً للأسطح الزجاجية. وتعزى الأحمال الداخلية إلى الركاب والإضاءة والمعدات. ومن خلال تجميع الإشعاع الشمسي، والتوصيل، والأحمال الداخلية، يحدد التقرير إجمالي تدفق الطاقة إلى الفيلا، والذي يتم من خلاله اشتقاق قدرة تكييف الهواء المطلوبة للحفاظ على الراحة الداخلية. توفر النتائج رؤى مهمة لتصميم أنظمة تبريد فعالة مصممة خصيصاً للظروف المناخية القاسية في الكويت.